Riverside Schoolboard Summary

Week of February 14, 2022

Number of connected schools: 23 Number of classrooms concerned: 380

CO₂ Summary

| | Number of classrooms | Percentage |
|---|----------------------|------------|
| Average concentration below 1 000 ppm | 321 | 84,5% |
| Average concentration between 1 000 and 1 500 ppm | 59 | 15,5% |
| Average concentration between 1 500 and 2 000 ppm | 0 | 0,0% |
| Average concentration above 2 000 ppm * | 0 | 0,0% |

^{*} Actions taken to remedy the situation:

Temperature Summary (optional)

| | Week of February 14 |
|---|---------------------|
| Average of weekly temperature average of all sensors | 21 |
| Number of rooms with weekly average temperature below 20 °C | 138 |
| Number of rooms with weekly average temperature between 20 °C and 26 °C | 241 |
| Number of rooms with weekly average temperature above 26 °C | 1 |